

COUNCIL AGENDA: JUNE 4, 2013

SUBJECT: CITY WELL #1A - EMERGENCY REPAIR

SOURCE: Public Works Department - Water Utilities Division

COMMENT: The City of Porterville Water Utilities Division maintains operation of City Well #1A located on Putnam Avenue east of Fourth Street.

The motor has failed and needs to be replaced. S.A. Camp Pump Company has indicated they can work us into their schedule immediately and recommends we lower the pump by 40 feet to avoid potential air problems.

It is critical that normal operation be restored and repairs be performed immediately to satisfy water system demands. The cost of replacement or repairs should not exceed \$35,000. Funding is available from the Water Replacement Fund.

RECOMMENDATION: That City Council approve emergency work to be completed by S.A. Camp Pump Company on City Well #1A at a cost not to exceed \$35,000.

P:\pubworks\General\Council\City Well #1A - Emergency Repair - 2013-06-04.doc

Dir Bsu Appropriated/Funded MS CM J

Item No. 9